

BAR SIZE	* LOCATION CATEGORY		
	A	B	C
#4	2'-11"	2'-1"	1'-8"
#5	3'-7"	2'-7"	2'-1"
#6	4'-4"	3'-1"	2'-6"
#7	5'-9"	Does Not Exist	3'-4"
#8	7'-7"		4'-4"
#9	9'-7"		5'-6"
#10	12'-2"		7'-0"
#11	14'-11"		8'-7"

* LOCATION CATEGORY

- A - Bars in horizontal layers in top of pour with 12" or more of concrete below them such as in: footings, pier caps, etc.
 B - All bars not in Category A spaced less than 6" apart.
 C - All bars not in Category A spaced 6" or more apart.

Note:

- When bar lap is not specified on the Plans, the above dimensions shall be used.
- These bar laps do not apply when bar is in lightweight concrete. Greater lengths are required for this material.
- These bar laps only apply where the General Notes indicate "Reinforcing Steel Design, $f_y = 60$ ksi."

CASE NO.2 - For bars coated with epoxy not in Case No.1.

APPROVAL	
<i>L.S. Friedman</i> DIRECTOR OFFICE OF STRUCTURES	
DATE: 2/2/90	
REVISIONS	
SHA	FHWA
11-23-93	-
1-22-01	-
9-20-05	-
11-26-07	-

FHWA APPROVAL
DATE:

STATE OF MARYLAND DEPARTMENT OF TRANSPORTATION STATE HIGHWAY ADMINISTRATION OFFICE OF STRUCTURES BAR LAP DIMENSIONS FOR GRADE 60 REINFORCING STEEL IN MIX NO.3 (3500 P.S.I.) CONCRETE EPOXY COATED REINFORCING CASE NO.2	
STANDARD NO. M(6.07)-81-127(L)	SHEET <u>3</u> OF <u>3</u>

